IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bill Josey DATE 6/11/75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 S. , T.R. at Freeze Store on Rd #1318, go approx ½ mile Mobile Home on Left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 115 X 200


Character & Porosity of Soil Red Clay loam

Percolation Rate more

Topography level

Depth to Water Table unknown

Rock or other impervious formations none found



Plot of System

Size of Tank 1,000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 560 Linear Ft. 225

Depth of Stone in Lines _____

Water Supply: Individual ( )

Public ( )

Installed by Lackey Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: This is an existing system, it should function under normal conditions.

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 6/11/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold