J. C. Clontz - Bedo

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Paul Wagner DATE 12/31/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 S. past Troutman. T.R. at Freeze Esso on Rd # 1318 Go approx. 2/10 Mile to House on R. S. R. No. _____

SUBDIVISION NAME Wagner Hts LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000 Sq. ft.


Character & Porosity of Soil Cecil Clay

Percolation Rate _____

Topography Slight Slope to North Side Low

Depth to Water Table _____

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Vernon Clontz

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface water and water from downspout should be diverted away from Septic Tank + lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12/31/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold