DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: Tindell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jacobs Woods, LLC
ADDRESS: Byers Road
PROPOSED FACILITY: 4 Bedroom House
PROPOSED DESIGN FLOW (.1949): 480gpd.
LOCATION OF SITE: Byers Road Lot 34
APPLICATION DATE 8/18/05
DATE EVALUATED: 8/19/Aug '0
PROPERTY SIZE: 0.77 Acres
PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
B 1	L/5-10	0-8	fr sbk / sc l	SS, SP, Fr SExP	NA	48"	NA	NA	PS 0.3
		8-36	SBK / C	SS SP, Fr SExP					
		36-48	WSBK / C	SS, SP, Fr SExP					
B 2	L/5-10	0-15	Gr / sl-scl	SS, SP, Fr SExP	NA Common Sap incl.	48"	NA	NA	PS 0.3
		15-48	WSBK / C	SS, SP, Fr SExP					
B 3	L/5-10	0-8	Gr / sl	NS, NP, Fr SExP	NA Few Sap incl	48"	NA	NA	PS 0.3
		8-34	SBK / C	SS, SP, Fr SExP					
		34-48	WSBK / CL	SS, SP, Fr					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	12005F	810 SF
System Type(s)	75% Red.	PPBPS
Site LTAR	0.3 gpd/ft²	0.3 gpd/ft²

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Ashley Rollins, LSS
OTHER(S) PRESENT:

COMMENTS: LUVISOLIC DELETED BORINGS ON 8-19-05