IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR S + N Leasing Co. DATE 9/28/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy. 21 S below Troutman, on right just beyond St. Michaels Cemetery. Troutman Roofing Co. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. 12

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
Site Suitable	Yes (✓)	No ( )	

Lot Area 2 acres


Character & Porosity of Soil Red clay

Percolation Rate _____

Topography slope to rear

Depth to Water Table low

Rock or other impervious formations none observed



Plot of System

Size of Tank ~~1000~~ 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 18"

Water Supply: Individual (✓)
Public ( )

Installed by Lackey

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Office building + warehouse to be built later. Do not more than 5 employees. Keep septic tank lines 15 ft. away from bank + fill dirt

CERTIFICATE OF COMPLETION BY Charles R. Hindler + Andrew E. Campe DATE 9/28/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold