12517.

IREDELL COUNTY HEALTH DEPARTMENT

on terminal 4L-1-A-12

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR NORTH POINT REALTY DATE 5-29-91. PERMIT NO. 4L-A-12.

PHONE: Business _____ Home _____

LOCATION Perry Rd. from Troutman. - go approx. one mile on (R) - Enter dev & go to end on left. S. R. No. _____

SUBDIVISION NAME PERRY HEIGHTS. LOT NO. 12. SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Prov. Suitable.
Percolation Rate 4 gal./sq. ft.
Topography 2-6% slope
Depth to Water Table 10+
Rock or other impervious formations none observed.

Lot Area approx. one acre.

_____ Basement with Plumbing _____ Basement without Plumbing (✓) No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Smith Bldrs.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 5-29-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold