12516.

IREDELL COUNTY HEALTH DEPARTMENT

39464

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR NORTH POINT REALTY DATE 5-30-91 PERMIT NO. 41-1-A-11

PHONE: Business _____ Home _____

LOCATION Perry Rd. from Troutman 2-ge approx. one mile on L-Esterdev.-Lucas on left near end. S. R. No. _____

SUBDIVISION NAME PERRY HEIGHTS. LOT NO. 11. SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clayey.
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4 gal pp. 10-9
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	None observed.

Lot Area 103' X 306'

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 960 Linear Ft. 320
Depth of Stone in Lines 12

Water Supply: Individual (✓)
Public ( )

Installed by Smith Builders

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 5-30-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold