13691

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR K.C. Development DATE 5-5-92 PERMIT NO. 46-1-AM

PHONE: Business _____ Home _____

LOCATION Perry Heights Lot 17 S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House [✓] Mobile Home [ ] Business [ ] Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes [ ] No [✓]

Auto. Dishwasher Yes [✓] No [ ]

Auto. Wash. Machine Yes [✓] No [ ]

Lot Area 100' X 300'+

Soil Characteristics Sandy clay


Application Rate .4

Topography 3 to 10%

Depth to Water Table 10'+

Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual [✓] Public [ ]

Installed by Sammy Reavis

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY J.C. moore

COMMENTS _____

CERTIFICATE OF COMPLETION BY J.C. moore DATE 5-5-92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold