DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES

DIVISION OF ENVIRONMENTAL HEALTH

ON-SITE WASTEWATER SECTION

SHEET: 1 of 2
PERMIT #:
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

OWNER/APPLICANT: Duncan Wiernn FOR Cathy Maddox
ADDRESS: 159 Level Drive.
~~PROPOSED~~ FACILITY: 3 BR SFD PROPOSED DESIGN FLOW (.1949): 360 GPD
LOCATION OF SITE: LOT 17 Perry Heights (Box #54)
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

APPLICATION DATE:
DATE EVALUATED: 09-15-06
PROPERTY SIZE: 0.7± Ac
PROPERTY RECORDED:

PROFILE #	.1940 LSCP PSTN/ SLOPE %	HORIZ DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L ~9%+	0-3	1,M,Gr, L/CL	Fr, SP, SEXP	N/A	~30"	Loam	N/A	(REPAIR) 0.25
		3-15	1,M,Sbk, C	Fr, SP, SEXP w/ COMMON MICA					
		15-34	1,M,Sbk, CL + SAP MIX	w/ COMMON - MANY MICA					
		34-48	L SAPROLITE w/ SOME CL SOIL MIX (≡ SDL SAP)	w/ common-many Mica					
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		REPAIR
System Type(s)		II REPAIR
Site LTAR		0.25 Repair

OTHER FACTORS (.1946): REPAIR
SITE CLASSIFICATION (.1948):
EVALUATED BY: P. Mitchell
OTHER(S) PRESENT:

COMMENTS:

(PAGE 2 ON REAR)

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL .1955 LTAR*	LPP .1957 LTAR*
CC (Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4
CV (Convex Slope)		LS (Loamy Sand)		
D (Drainage Way)				
DS (Debris Slump)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3
FP (Flood Plain)		L (Loam)		
FS (Foot Slope)				
H (Head Slope)	III	Si (Silt)	0.6 - 0.3	0.3 - 0.15
L (Linear Slope)		SiCL (Silty Clay Loam)		
N (Nose Slope)		CL (Clay Loam)		
R (Ridge)		SCL (Sandy Clay Loam)		
S (Shoulder Slope)		SiL (Silt Loam)		
T (Terrace)				
	IV	C (Clay)	0.4 - 0.1	0.2 - 0.05
		SC (Sandy Clay)		
		SiC (Silty Clay)		
		O (Organic)	None	None

MINERALOGY/ CONSISTENCE
NEXP (Non-expansive)
SEXP (Slightly Expansive)
EXP (Expansive)

MOIST
VFR (Very Friable)
FR (Friable)
FI (Firm)
VFI (Very Firm)
EFI (Extremely Firm)

WET
NS (Non Sticky)
SS (Slightly Sticky)
MS (Mod. Sticky)
VS (Very Sticky)

NP (Non Plastic)
SP (Slightly Plastic)
MP (Mod. Plastic)
VP (Very Plastic)

STRUCTURE TYPE
G (Single Grain) [*Structureless*]
M (Massive) [*Structureless*]
CR (Crumb)
GR (Granular)
SBK (Subangular Blocky)
ABK (Angular Blocky)
PL (Platy)
PR (Prismatic)
COL (Columnar)
CMPD (Compound) [___ parting to ___]

STRUCTURE GRADE
0 (Strucutreless)
1 (Weak)
2 (Moderate)
3 (Strong)

STRUCTURE CLASS
VF (Very Fine)
F (Fine)
M (Medium)
C (Coarse)
VC (Very Coarse)

***Adjust LTAR due to depth, consistence, structure, soil wetness, landscape position, wastewater flow and quality.**

NOTES

HORIZON DEPTH	In inches below natural soil surface
DEPTH OF FILL	In inches from land surface
RESTRICTIVE HORIZON	Thickness and depth from land surface
SAPROLITE	S(suitable) or U(unsuitable)
SOIL WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
CLASSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

*** Evaluation of saprolite shall be by pits.**

Long-term Acceptance Rate (LTAR): gal/day/ft^2

Show profile locations and other site features (dimensions, reference or benchmark, and North).

