DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Laura Barry OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 7-25-94
PROPOSED FACILITY:
PROPERTY SIZE:

LOCATION OF SITE:
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other: EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINERALOGY		
1	10 to 12% Somewhat complex	0 to 5	L	GR		.1942 WETNESS CONDITION	N/A
		5 to 24	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		24 to 48	Transition			.1944 RESTRICTIVE HORIZON	N/A
						.1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	10 to 12% complex	0 to 5	L	GR		.1942 WETNESS CONDITION	N/A
		5 to 24	C	SBK	1:1	.1943/.1956 SAPROLITE	~~[illegible]~~ 36"
		24 to 36	Transition			.1944 RESTRICTIVE HORIZON	N/A
		36 to 48	Saprolite			.1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3	6 to 8%	0 to 5	L	GR		.1942 WETNESS CONDITION	N/A
		5 to 48	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
						.1944 RESTRICTIVE HORIZON	N/A
						.1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1945 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1945 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1943): PS SITE LONG-TERM ACCEPTANCE RATE: PS
OTHER FACTORS(.1946) SYSTEM TYPE: conv. Gravity
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: ~~Erosion Factors in~~
COMMENTS: Erosion Factors in Each Yard

DRAF

0 0 0 0 9 5