07583

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR L.C. PERRY DATE 4-26-89 PERMIT NO. 156.

PHONE: Business _____ Home _____

LOCATION Perry Rd. S. R. No. _____

SUBDIVISION NAME PERRY PARK. LOT NO. 24 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Loamy Sand to Sandy Loam

Percolation Rate 2 Min. per Inch

Topography Slope 10+

Depth to Water Table 10+

Rock or other impervious formations None observed.


Lot Area 24,000 sq. ft.

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by J.C. Forsyth

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J.C. Massa

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-26-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold