17563

KENDALL COUNTY HEALTH DEPARTMENT

SEPTIC TANK IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION

Disposal Absorption Sewage Disposal System U.S. Chapter 17 Illinois Plumbing Code

OWNER OR CONTRACTOR [illegible] DATE 4-26-89 PERMIT NO. 1356

PHONE Builder

LOCATION Bluff Rd.

SUBDIVISION NAME Deer Park LOT NO. 22 SECTION OR BLOCK NO.

Home 1 Mobile Home Business Other

No. Bedrooms 3 Capacity of Pumping Tank 750 Gal.

Garbage Disposal Unit Yes No Percolation Rate 5-20 M.P.I.

Auto. Dishwasher Yes No Topography Level

Auto. Wash Machine Yes No Depth to Water Table 12+

Site Suitable Yes No Rock or other impervious formations None Encountered

Lot Area 1 Acre Basement with Plumbing Basement without Plumbing No Basement


Size of Tank 1000 Gal.

Absorption Field: 2

No. of Lines 2 Length of Lines 50 Ft.

Depth of Stone 24 Inches Total Area 200 Sq. Ft.

Water Supply Individual Well



The proposed Above-ground pool addition does not appear to impact the existing septic system.

**NOTE: Keep 15ft. ± from exist. system.

[illegible], R.S.

Date: 8 July 89

ICHD-Environmental Health Division

FEB. 26, 1989 2:40