SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: W. BREWSTER APPLICANT: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____

LOCATION OF SITE: MARTHAS VINEYARD LOT 37 PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-8	B SCL SHM	FR SSSP					PS 3
	8-26	BL SHM/MOD	FI SSP - FEW YB					
	26-50	YBCL MSHM	FM SSSP - FEW SAP					
	0-6	RS SCL MSHM/GR	FRI SSSP					PS 3
	6-30	RL SSHM/MOD	FI SP					
	30-48	YR CL MSHM	FRI SSSP - FEW SAP					

Usable Space (.1943)