IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 100655 PIN# ~~4744-78-8448~~ 4741-87-4223 DATE 4-7-04

OWNER OR CONTRACTOR William BREWSTER PHONE: Business 895-0556 Home 0006 704-400-5066

ADDRESS P.O. Box 99 DAVIDSON, NC 28036

LOCATION 21 S (L) MUDDOCK (R) HOOVER (C) MARTHA VINEYARD (C) PAINTED BUNTING AT END ON LEFT

SUBDIVISION MARTHA VINEYARD BLOCK / SECTION ____ LOT 23 LOT AREA 2.105 AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .35

Septic Tank: 1000 Gallons; STB 0062 Date 5-01-04

Pump Tank: 1000 Gallons; PT 77 Date 6-16-04

Pump Make: GOULDS Model WE0111H Serial No. S0540182-8

Nitrification Field: No Fields 1 Square Feet 1371 Linear Feet 232'

No Lines 4X58' Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LOW PRESS SD1.1200

Repair System Description: LPP

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms 2.5 No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: ☆ BUILDER OK'D TANK & SYSTEM CHANGES

Comments:/Conditions: (1) THIS IS A REDRAW PERMIT. ONLY CHANGES WERE SYSTEM TYPE & BEDROOMS. PERMIT REDRAWN USING CRITERIA FROM PREVIOUS ISSUED PERMIT ISSUED BY BRADY FREEMAN, R.S. ON 10-5-01; SYSTEM WILL BE IN SAME LOCATION

PROGRAM SPECIALIST

INITIAL SITE SKETCH

1" = 60'

DRIVE

24'

40'

HOUSE SITE

8'x12'

PAINTED BUNTING

CENTER LINE BOX

REPAIR

2' x 58'

2' x 58'

2' x 58'

2' x 58'

SOILS

AS BUILT SKETCH

(2) MAINTAIN SETBACKS @ LOTS 23 & 24 COMBINED ON PLAT AS LOT 23 AS SPECIFIED

EVALUATED OUT SYSTEM & UNLOCATED TANKS @ 10-6-04. CONTOURS CHANGED;

- NEED SYSTEM & TANK CHANGES APPROVAL

- SYSTEM INSTALLED IN SAME LOCATION

- LINE LENGTHS CHANGED DUE TO CONTOURS

STILL HAS 232'

"NOT" TO "SCALE"

12-8-04

V'D LINES & PRESSURE

V'D ELECTRICAL

CONTENT & SPACING OF DRAIN IS OK.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 9/8/04

Improvement Permit by: [signature] date 9-7-04

Issued by: [signature] date 9-7-04

Installed by: A-1 BACKHOE

Operation Permit by: [signature] date 12-16-04

Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK