IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 176933

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4742385651

APPLICANT: Stanley Childers APPLICANT ADDRESS: 104 Wintergreen Cir

SITE ADDRESS: 104 Wintergreen Cir PHONE: 704-576-0369 ALT. PHONE: N/A

SITE DIRECTIONS: Hwy 21S TL Amity Hill Rd. TR Moose Club Rd. TL Duck Creek Rd. TL Wintergreen Cir.

SUBDIVISION: N/A SECTION: N/A LOT # N/A LOT AREA: 1.54 acres DESIGN FLOW: 360gpd L.T.A.R.: 0.25

Septic Tank 1000 (gal) STB 760 Date 9-23
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 3 Linear Ft: 316
Trench Width 36" Max. Trench Bottom Depth 32" Gravel Depth N/A

☐ New System ☑ Repair ☐ Expansion System Type: I II III IV V VI
System Description:
Repair System Description: 25% Reduction
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE


☑ Residence No. Bedrooms 3
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☑ Crawl Space
☑ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: Pump & crush old septic tank & Install a 25% reduction system on contour with serial distribution

- Grade out small water diversion ditch above new drainfield area
- New septic tank is 20' from house foundation. last.

INITIAL SITE SKETCH



A SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** ***with plat*** *valid without expiration.* ☑ **IMPROVEMENT PERMIT** ***with site plan*** *valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: James Stanley Childers Date: 2-7-13 Installed by: A1 Backhoe

IMPROVEMENT PERMIT by: Justin Henderson Date: 2-6-13 OPERATION PERMIT by: Justin Henderson Date: 2-25-13

AUTHORIZATION TO CONSTRUCT by: Justin Henderson Date: 2-6-13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK