DEPARTMENT OF ENVIRONMENTAL HEALTH
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY COUN

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

TRANSMAN
4742-42-32
4742-42-556

OWNER: INV: ASSET MNGMT INC APPLICANT: CHRIS WENDT
ADDRESS: 135 ENTERPRISE LANE ~~TOWNMARK~~ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: HOUSE PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 10.08AC
LOCATION OF SITE: MOORE, HOOVER 1820 LOT ONLY PROPERTY RECORDED: YES
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	8% L	0-6"	scl topsoil			748'			PS .3
		6-48'	c mod sbk	fi sp scap					
2	8% L	0-6"	scl topsoil			748"			PS .3
		6-48'	c mod sbk	fi sp scap					
3	8% L	0-6	scl topsoil			748'			PS .3
		6-48'	c mod sbk	fi sp scap					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	CONV 480	CONV 25%
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: C. WENDT