IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Allen Edmiston DATE 6-24-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Newtown – Murdock Rd – to Silo Acres

S. R. No. _____

SUBDIVISION NAME Silo Acres LOT NO. 33 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Red Clay


Percolation Rate none

Topography Slight slope to left side

Depth to Water Table none

Rock or other impervious formations none

Lot Area 80,000



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Stewart

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface water should be diverted away from Septic tank system.

CERTIFICATE OF COMPLETION BY Glenn Todd DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold