IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Stacy St. John DATE 4/14/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21S., T.L. on Rd #2342 (Cattle Barn Rd), cross 3rd creek and to near intersection of Rd # 2348 - house on Rt S. R. No. 2342


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	CfBa
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	none
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-10% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25
			Rock or other impervious formations	none observed

Lot Area .77 acres



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by, Hole Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Campe DATE April 14, 1977

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold