IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rudy Kinlaw & Murdock DATE 5-10-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77 - South - Turn Rt Amity Hill Rd - Then left on Murdock Rd Mobile Home behind 4th Brick House on Lt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area INCREASE


Character & Porosity of Soil Red Clay

Percolation Rate 1 min

Topography Slope to Rear

Depth to Water Table 4 feet

Rock or other impervious formations None



Shot of System →

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Sam Bettwest

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 5/10/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold