IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David Englehart DATE 3-5-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Silo Acres - Hamilton Rd.

S. R. No. _____


SUBDIVISION NAME Silo Acres LOT NO. 7 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Coarse Clay Loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to back
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	20+
			Rock or other impervious formations	None

Lot Area 1/2 Acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 20"

Water Supply: Individual (✓)

Public ( )

Installed by Hope Bros. Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: Back yard should be graded to have plenty cover over Nitrification field

CERTIFICATE OF COMPLETION BY _____ DATE 3/5/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold