DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION (704) 838-0622
for ON-SITE WASTEWATER SYSTEM

OWNER: Robert Hall APPLICANT: Robert Hall
ADDRESS: 128 Secrest Dive Troutman APPLICATION DATE: _____ DATE EVALUATED: 5/16/01
PROPOSED FACILITY: 3BR House/Com Space PROPOSED DESIGN FLOW (.1949): 360 gal/d PROPERTY SIZE: 2 ± 3 Acres
LOCATION OF SITE: _____ PROPERTY RECORDED: X
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	12% Linear	0-2"	scl	SFr SPy					.25
		2-35"	cl msbk	Fi SP SEy					
		35-48"	scl wpbk	FiFr SS SP SEy					
2	13% None	0-36"	cl sbk	Fi SP SEy					.2
		36-49"	cl sp wsbk	FiFr SSP SEy					
3	20% Linear	0-24"	c msbk	Fi Sp SEy					.2
		24-40"	cl wsbk w sbk	FiFr SSP SEy					
		40-49"	scp wsbk	FiFr SSP SEy					
4	12% None	0-4	scl wpbk	FrVFr SSP SEy					.2
		4-36"	cl sbk	FiFr SSP SEy					
		36-49"	cl	FiFr SSP SEy					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	R	R
System Type(s)	Conv. Gravity	Pump 50% Red
Site LTAR	.2	.2

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____