IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281 4 [illegible]

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 067023 DATE June 26, 97 TAX MAP NO. 4742930160 Watershed: ☐ Yes ☐ No

OWNER OR CONTRACTOR CRTS PHONE: Business Home

ADDRESS 2925 Hunteigh Dr Suite 201 Raleigh

LOCATION I-77 S. from Statesville Getoff Amity Hill Rd Exit TL (east) X interstate on Right

SUBDIVISION BLOCK / SECTION LOT LOT AREA .8Ac SITE CLASS. PS DESIGN FLOW 450gpd L.T.A.R. .3

Septic Tank: 1500 Gallons; STB 997 Date 3-9-97

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 5&6 Trench Width 36" Max Trench Bottom Depth (24") Gravel Depth NA

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: gravity plastic chamber

Repair System Description: same

Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod. Home ☐ Mobile Home ☑ Business ☐ Other

No. Bedrooms No. Bathrooms No. Employees 18

☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Community ☐ Public

Comments: No paving/parking over septic tank. Supply line through parking area to be >36".

Comments: 3-31-98 Inspected drain lines only 6 lines total of 400 ft not

INITIAL SITE SKETCH

SEE Plan by TC Jacobs & Assoc.

AS BUILT SKETCH

Same as initial Sketch

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit, any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed:

Improvement Permit by: [signature] date 6-26-97

Inspection System Inspection by: [signature] date 6-26-97

Installed by: James Hufler

Certificate of Completion by: date

Operation Permit by: C. C. Moore date 4-6-98

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD