DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

18 BDRM x 250 / = 450 gpd

OWNER: CKTS
ADDRESS: ___
APPLICANT: ___
APPLICATION DATE: ___
DATE EVALUATED: 6-7-22
PROPOSED FACILITY: Trailer Service
PROPOSED DESIGN FLOW (.1949): 450 gpd
PROPERTY SIZE: 7.9 Ac
LOCATION OF SITE: EXIT 45 off 77 72 2nd right
PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	L	0-17	mod blk R fri	SS sm clay lo					V5 .3
		17-36	wk blk vfr sch	fr sl clay lo					
		36-50	LG/SAP wet						
2	L	0-12	gr sl sand SL						
		12-36	mott sb blocky fr lo						
		36-48	mott sb blocky fr lo						
			mod SAP						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___