IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Terry Mills DATE 9-21-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77S TL on Amity Hill Rd TL Towards KOA Campground Then TR past KOA house on R S. R. No. 2351

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 4 acres

Character & Porosity of Soil Cecil clay loam
Percolation Rate 1 @ gal / sq' app rate
Topography 2 to 4%
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles
Mooresville

IMPROVEMENTS PERMIT BY Andrew Causey

COMMENTS: Rained in system before had a chance to cover. Backfill but do not pack or landscape till try.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 9-21-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold