IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Grady Poteat DATE April 8, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21S, on left before Kimball St (white brick House

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 4

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area _____

Character & Porosity of Soil CfC2


Percolation Rate none

Topography 6-10% Slope to Rt side

Depth to Water Table wet

Rock or other impervious formations none observed

Repaired



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 400
Depth of Stone in Lines 10" BT

Water Supply: Individual ( )
Public (✓)

Installed by Hoover Sysson

IMPROVEMENTS PERMIT BY _____

COMMENTS: extra wide + stone depth - good soil encountered in pit

CERTIFICATE OF COMPLETION BY Andrew E. Canup DATE April 8, 1977

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold