IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Cobb DATE 7-9-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US 70E TR on Barkley Rd before end of Rd on R. S. R. No. _____


SUBDIVISION NAME Glenn Echo LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Adding room to house where old system was located

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	.6 gal/sq ft
Auto. Wash. Machine	Yes ( )	No ( )	Topography	2 to 6 %
Site Suitable	Yes ( )	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	None

Lot Area _____



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 780 Linear Ft. 260
Depth of Stone in Lines 20"
Water Supply: Individual ( )
Public (✓)

Installed by Paul Frye Son

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: landscape so that surface water will not stand over tank or lines.

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 7-9-81

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold