IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Pat Kleinhaus DATE 1-19-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E TR on Barkley Rd TR on Deal St 3rd house on right S. R. No. _____


SUBDIVISION NAME Glenn Echo LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Cecil clay
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	Est. 60 min/1 inch
Auto. Wash. Machine	Yes ( )	No ( )	Topography	2 to 6%
Site Suitable	Yes ( )	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	None

Lot Area 1/2 acre



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)
+ 16 Ton Pit

Installed by _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: divert all surface & gutter water around Drain Fields

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 1-19-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold