IREDELL COUNTY HEALTH DEPARTMENT

County Building | Phone 1164 | Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. 422 Permit Date 9-2 194 8

Owner Hebron Presb. Church Address Off Davidson St.

Tenant Rev. W. N. Williams, Address

Installed by Clyde Wakefield Address

Location of Property Salem

Kind of Tank Concrete Capacity Covenant Length of trench 200'


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection .....194.... Approved ( ) Disapproved ( )

Remarks:

First five feet of line from outlet should be of cast iron soil pipe.



Chas. Butler
Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.