IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Miller DATE 1-16-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Salisbury Rd TL on Greenway Then TL on Stoneybrook 100' on L

SUBDIVISION NAME Old Country Club area LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1 acre +

Character & Porosity of Soil Clay Class IV-A
Percolation Rate 14 gal/sq.ft/day
Topography Sloping
Depth to Water Table 10'+
Rock or other impervious formations none



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines [redacted] 16 to 18"
Water Supply: Individual ( )
Public (✓)

Installed by Paul Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 1-16-84

EXISTING SYSTEM CHECKED BY: R. C. Moore DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold