IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR East Side Baptist Church DATE 4-14-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION East Side Rd. + Marlowe St.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other Church

No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Percolation Rate	Fast
Auto. Dishwasher	Yes ( )	No ( )	Topography	2 - 6% Slope
Auto. Wash. Machine	Yes ( )	No ( )	Depth to Water Table	Unk
Site Suitable	Yes ( )	No ( )	Rock or other impervious formations	None

Character & Porosity of Soil C Fbr

Lot Area _____



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 250 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Wes Lytton

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd, DATE 4/4/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold