IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR McMillan Mini Mart Hope Bros Builders DATE 11-14-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E - on left past traffic light at Barkley Rd. S. R. No. 2052

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (4) Other _____

No. Bedrooms _____ No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____


Character & Porosity of Soil Red Clay

Percolation Rate slow

Topography level

Depth to Water Table 25+

Rock or other impervious formations none noted



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 186 Linear Ft. 62

Depth of Stone in Lines 16"+4

Water Supply: Individual ( )
Public ( )

Installed by Hope Bros. Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: Temporary System -

CERTIFICATE OF COMPLETION BY _____ DATE 11/14/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold