IREDELL COUNTY HEALTH DEPARTMENT

B&B. Edward & Bonnie

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bill Beam DATE 23 Oct 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Broad St to East Side Dr on Left. Go to 2nd St on Left. (# 2408) Go approx ¼ mi - House on Left. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay Loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	none	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Steep Slope to rear and left of house	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	ud	
			Rock or other impervious formations	ud	

Lot Area _____



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by James Hartsoe

IMPROVEMENTS PERMIT BY _____

COMMENTS: 7" fall. need some additional cover with fine grading

CERTIFICATE OF COMPLETION BY Will Lucas DATE 23 Oct 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold