IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Stafford DATE 10-12-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Sullivan Rd Turn on Dogwood Lane at end of Street on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 15,000 sq'

Character & Porosity of Soil Cecil Sandy clay
Percolation Rate 80 min/inch
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: Landscape & pipe Gutters so that water will not be channeled into area of septic Tank system.

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 10-12-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold