DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 4745593021
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Larry Pittman
ADDRESS: 163 James Farm Rd
PROPOSED FACILITY: 3BD
LOCATION OF SITE: 21N to James Farm Rd
PROPOSED DESIGN FLOW (.1949): 240
APPLICATION DATE 05/12/14
DATE EVALUATED: 06/06/14
PROPERTY SIZE: 1.6 ac
PROPERTY RECORDED: Yes
WATER SUPPLY: • Private • Public • Well • Spring • Other N/A
EVALUATION METHOD: Auger Boring • Pit • Cut
TYPE OF WASTEWATER: Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 4%	0-30	C fi	SBK SF	PS	PS	W/A	W/A	PS .3
		30-48	BC fi/fr	WABK SF					
2	L 10%	0-36	C fi	SBK SF	PS	PS	W/A	W/A	PS .3
		30-48	BC fi/fr	WABK SF					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)		PS
'stem Type(s)		25%
e LTAR		.3

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: H Snow
OTHER(S) PRESENT:

IMENTS: