4049D

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

13014

OWNER OR CONTRACTOR JAMES M. WILHELM DATE 1/29/92 PERMIT NO. 10C-A-117

PHONE: Business _____ Home _____

LOCATION US 21 N, TL FT. DOBBS ROAD, TR COOPER FARM RD, 3RD GRAVEL DRIVE ON (R), TO END. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 10.55 AC

Character & Porosity of Soil PS
Percolation Rate .4 GPD/FT2
Topography 2-5%
Depth to Water Table >4'
Rock or other impervious formations NONE

SHED


(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement

ACP 9/21/91

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual (✓) WELL
Public ( )



Plot of System

Installed by DAVID YOUNTS

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY JIC/ MOORE

COMMENTS: _____

COOPER FARM ROAD

CERTIFICATE OF COMPLETION BY STEVE HERRICK DATE 1/29/92

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold