IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. A. Stafford DATE 4-23-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Fairdale Heights - Bettie Lane end of St.
TL - about 200 ft. from St. S. R. No. 1971


SUBDIVISION NAME Fairdale Heights LOT NO. _____ SECTION OR BLOCK NO. _____
C. C. Dilley Property

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Cecil Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	1 in 5 min	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope To Back	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25+	
			Rock or other impervious formations	None	

Lot Area 100 x 200



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hoke Septic Tank Service

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd Jr. DATE 4/23/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold