IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas Coley DATE 4-20-87 PERMIT NO. 11A.

PHONE: Business _____ Home _____

LOCATION 418 Devon Dr. off Nixon Rd. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Ample.

Character & Porosity of Soil Clayey
Percolation Rate Legal page 4
Topography Level to Gently
Depth to Water Table 10'+
Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 120 Linear Ft. 240
Depth of Stone in Lines 12 +

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Young

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Howell

COMMENTS: Bull Run Valve installed

CERTIFICATE OF COMPLETION BY Jim Brown DATE 4-20-87.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold