IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Fortis Corp DATE 3-9-82 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Kingswood Lot 9

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil Clay loam

Percolation Rate 15 gal/sq'/60 days


Topography 2 to 6% Slope

Depth to Water Table 10'+

Rock or other impervious formations none

Lot Area 1/2 acre

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System Street

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Pfaff Septic Tank Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Ground water was coming into lines grade lot so all water will be divertted around lines. may require a French Drain if Drain lines continue to take on ground water.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 3-9-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

ermit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making
provements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold