IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JB Fennater DATE 18 Oct 73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21N & Fort Dobbs Rd. 4th lot on Rgt

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 36,100 sq ft


Character & Porosity of Soil Red Clay

Percolation Rate none

Topography Level

Depth to Water Table none

Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines _____

Water Supply: Individual ( )

Public (✓)

Installed by Herbie Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Owner had extra line added - Fell apart. Ditch a little to owner.

CERTIFICATE OF COMPLETION BY William M. Tennant DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold