DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: C.C.S. Inc (Richard Wood) APPLICANT: Richard Wood
ADDRESS: _____ APPLICATION DATE: 2/9/01 DATE EVALUATED: 2/28/01
PROPOSED FACILITY: 3BR House/Crawl PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .57 Acres
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Lot #3

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	2% Linear	0-16	ce m SBK						PS .35
		16-30	ce wf micx wSBK						
		30-48	ce w Sap/micx Heavy wSBK						
2	Linear 2%	0-15	ce m SBK						PS .35
		15-30	ce Heavy w SBK micx						
		30-48	ce Heavy micx/Sap wSBK						
3	Linear 6%	0-12	ce m SBK						PS .35
		12-22	ce w Heavy Sap wSBK						
		22-32	Cg w Mott/Sap wSBK						
		32-48	Sap Heavy micx						
4					10YR 5/3 25Y				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv. Trench	Rotary 24" Trench
Site LTAR	.35	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Lucas
OTHER(S) PRESENT: _____