IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Alfred Levan DATE 6-26-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Debbie Lane - Iredell Heights - 1st House on left across stream S. R. No. _____


SUBDIVISION NAME Iredell Heights LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	yellow red clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate		
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to R side	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table		
			Rock or other impervious formations	None	

Lot Area ½ Acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)
Iredell Water Corp.

Installed by Herman Gibson

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Herman Gibson DATE 6/26/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold