IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Liles DATE June 29 '78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1808 Debbie Lane


SUBDIVISION NAME Iredell Heights LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes ( )	No ( )	Topography	
Site Suitable	Yes ( )	No ( )	Depth to Water Table	
			Rock or other impervious formations	

Lot Area _____



Plot of System

Size of Tank existing Gals.
Nitrification Field: 1
No. of Lines
Sq. Ft. 270 Linear Ft. 90
Depth of Stone in Lines 16" ±
Water Supply: Individual ( )
Public (✓)

Installed by Jam Asphalt

IMPROVEMENTS PERMIT BY Glenn Fox Jr.

COMMENTS: Old line cut off at point of malfunction and packed w/ dirt.

CERTIFICATE OF COMPLETION BY David R. Hinson DATE June 29 '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold