IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Hope DATE 8-28-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N TL on Shoemaker Dr. TL on Debbie Lane 6th on left S. R. No. _____


SUBDIVISION NAME Iredell Heights LOT NO. 17-20 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	LfBz	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	5cm to mot.	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
			Rock or other impervious formations	none	

Lot Area 20,000 Sq feet



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines _____

Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros.
Arnie Duncan

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 8-28-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold