IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Carl White DATE 12-4-13 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Iredell Heights – Victoria Drive – Dread Rd –

S. R. No. _____


SUBDIVISION NAME Iredell Heights LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Slight to Moderate
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight to Moderate
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	

Lot Area 3/4 Acre



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 702½ Linear Ft. 283
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by York Rafty
Stony Point, N.C.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Tank has 4' stand pipe with cover. Tank is set deep 5' cover.

CERTIFICATE OF COMPLETION BY _____ DATE 12/4/13

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold