IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros Builders DATE 11-29-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Iredell Heights - Victoria Dr. 2nd house on Rt from Debbie Lane S. R. No. _____


SUBDIVISION NAME Iredell Heights LOT NO. 198 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Hard Red Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Fast
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to front
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	—
			Rock or other impervious formations	—

Lot Area 23,962



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 832 Linear Ft. 277
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros Inc.
Statesville, N.C.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Soil is tight - Hard Red Clay

CERTIFICATE OF COMPLETION BY Glenn Tate DATE 11-29-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold