IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Hope DATE 5-16-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Victoria Dr.


S. R. No. _____

SUBDIVISION NAME Dudue Heights LOT NO. 173-176 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____ Mar. Suitable

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil		a Tsr
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate		Good
Auto. Wash. Machine	Yes (✓)	No ( )	Topography		2-6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table		Some
Lot Area _____			Rock or other impervious formations		Some



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 18"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros. Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 5/16/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold