IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles R. Poplin DATE 11/13/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 409 Victoria Drive S. R. No. _____

SUBDIVISION NAME Iredell Heights LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area ½ acres

Character & Porosity of Soil Cecil Clay loam
Percolation Rate 90 min per"
Topography 2% - 3% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 500 Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 375 Linear Ft. 125
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

8 ton at end of old line – all ready covered

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 11/14/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold