IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Reality DATE 4-24-80 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION US 21 N Tl on Shoemaker Rd Tl on Ginny Lane at cornor of Ginny circle S. R. No. _____

SUBDIVISION NAME Iredell Height LOT NO. 23 SECTION OR BLOCK NO. 3

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 139' X 154'

Character & Porosity of Soil Cecil clay
Percolation Rate 100 to 120
Topography 2 to 6 %
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 700 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz Son

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: Lantscape & pipe Gutters so that surface water will not stand over Tank or lines

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 4-24-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold