IREDELL COUNTY HEALTH DEPARTMENT

Add. Lake Pratt

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Stevenson DATE 25 Mar 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Shumate Dr. to addition at end of Heights S. R. No. _____

SUBDIVISION NAME _____ LOT NO. # 17 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 18,000 sq ft.


Character & Porosity of Soil Red Clay

Percolation Rate slow

Topography Slope to rear of home

Depth to Water Table ok

Rock or other impervious formations ok



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 18"

Water Supply: Individual ( )
Public (✓)

Installed by Webb Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wm Howard DATE 25 Mar 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold