IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wayne Plyler DATE 10-24-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US 21 N 5th house on left Past white Oaks


S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	120 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area 1/2 acre			Rock or other impervious formations	none



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)
18 Ton rock Pit at end of lines
Installed by Paul Frye

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: Pipe Gutters + landscape so water will not stand over Tank or lines

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 10-24-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold