IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eagle Home Builders DATE 10-18-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N TR on Jane Sowers Rd Turn 1st R Then TR again 2nd lot on left, S. R. No. _____

SUBDIVISION NAME Sherwood Forest LOT NO. 8 SECTION OR BLOCK NO. II


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 acre

Character & Porosity of Soil Cecil Fine Sandy clay Li
Percolation Rate 60 to 80 min/inch
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: landscape + pipe Gutters so water will not stand over Tank or lines

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 10-18-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold